



CITY OF NORTHAMPTON, MASSACHUSETTS  
DEPARTMENT OF PUBLIC WORKS  
125 Locust Street  
Northampton, MA 01060

413-587-1570  
Fax 413-587-1576

Donna LaScaleia  
Director

## Memorandum

---

To: Donna LaScaleia, DPW Director *Approved M 3-25-2022*  
From: Greg Newman, Senior Civil Engineer  
Date: March 24, 2022  
Re: Petition No. 30363546 to install a Pole near 541 Ryan Road

---

National Grid is proposing to install one SO stub pole #54-84 on Ryan Road, beginning at a point approximately "52 feet southwest" of the intersection of Brookside Circle and Ryan Road centerlines. As staked, the pole will be south of the driveway to 541 Ryan Road.

A review of City records indicates the following:

1. There are no City drainage facilities near the proposed location.
2. There are no conflicts with City water facilities; the water service for 541 Ryan Road is located more than 100-ft from the region of the proposed pole location (based on water service tie cards).
3. The sewer service lateral to 541 Ryan Road is located in the area of the driveway entrance to #541, based on a review of the as-built plan (circa 1963). The proposed pole location, as staked, has no apparent conflict with the sewer service to #541.

*A Northampton DPW Trench Permit is required prior to construction. At that time, the approximate location of the City sewer service to 541 Ryan Road will be marked in the street. **If the proposed pole location is within 10-feet of the sewer as marked out by City's Sewer Foreman, the permit will require that DPW Engineers check the separation distance between the sewer service and proposed pole.***