




CITY OF NORTHAMPTON, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS
125 Locust Street
Northampton, MA 01060

413-587-1570
Fax 413-587-1576

Donna LaScaleia
Director

Memorandum

To: Donna LaScaleia, DPW Director *Approved 9-1-2022* 

From: Greg Newman, Senior Civil Engineer

Date: September 1, 2022

Re: Petition No. 30570025 to install one JO stub pole & anchor on Willow Street

National Grid is proposing to install (1) JO stub pole and anchor on Willow Street beginning at a point approximately 440 feet southeast of the centerline of the intersection of Bliss St to replace an existing guy.

A review of City records indicates the following:

1. There are no City drainage facilities near the proposed pole and anchor locations.
2. There are no City water facilities near the proposed pole and anchor locations.
3. There are City sewer facilities in the paved street that may be located less than 10 feet (but more than 5 feet) from the proposed pole location. The sewer service to the house appears to be located more than 10 feet away from the proposed pole and anchor locations.

Based on the above, there appears to be no conflict with City utilities at the proposed pole and anchor locations.

A Northampton DPW Trench Permit is required prior to construction.