



**CITY OF NORTHAMPTON, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS
125 Locust Street
Northampton, MA 01060**

**413-587-1570
Fax 413-587-1576**

**Donna LaScaleia
Director**

Memorandum

To: Donna LaScaleia, DPW Director *Approved 6-1-2023*
From: Greg Newman, DPW Senior Engineer
Date: May 30, 2023
Re: Petition 11460 to install one (1) Telemetry Cabinet and conduit on South Street

Eversource has installed a control cabinet, telemetry cabinet, and associated power and telemetry conduit with connection to pole #56 in South Street. The location is about 95-feet west of the west entrance to South Park Terrace.

A review of City records indicates the following:

1. SEWER. There no sewer service in the vicinity of the work.
2. WATER. There is a water main in South Street that is located about 7-ft from the cabinets and conduits.
3. DRAIN. There is a drain in South Street that is located about 10-ft from the cabinets and conduit. ,
4. OTHER – Sidewalks & Trees. The existing facilities are located south of the existing sidewalk. There are some large trees located behind the cabinets that may have been impacted by the work. The impacts were limited since the facilities were constructed in close proximity to pole #56.

Based on the above, there are no significant conflicts with SEWER, WATER & DRAIN utilities for this work.

Layout of the control cabinet, telemetry cabinets, bollards and connections to the adjacent pole are apparent in the attached photo.

