



CITY OF NORTHAMPTON, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS
125 Locust Street
Northampton, MA 01060

413-587-1570
Fax 413-587-1576

Donna LaScaleia
Director

Memorandum

To: Donna LaScaleia, DPW Director *Approved PL 12-22-25*
From: Kris Baker, P.E.
Date: December 18, 2025
Re: National Grid Pole Petition #31165186 – Hawley Street Pole #15 & Pole #15-50

National Grid is proposing to install 1 JO Pole on Hawley Street and relocate 1 JO on Hawley Street beginning at a point approximately 56 feet north of the centerline of the intersection of Isabella Street and continuing approximately 25 feet in a northern direction, to relocate existing Pole #15 approximately 12 feet south and to install a new midspan pole #15-50 approximately 37 feet south of existing pole #15.

A review of City records indicates the following:

1. **WATER & SEWER:** The water and sewer mains in Hawley Street are located on the east side of the roadway. No conflicts are anticipated with the proposed pole locations. There are sewer stubs and a water service that has been disconnected in the vicinity of Pole #15 that should be avoided.
2. **DRAIN:** The drainage system is located within the paved roadway and no conflict is anticipated.
3. **PUBLIC SHADE TREES:** Public shade trees are not located within the work area.

A Northampton DPW Trench Permit is required prior to any construction.